

PrestiVac Inc.
4499 Boul. Des Grandes-Prairies
Montreal, Quebec (Canada)
H1A 1R5

FILTRATION CERTIFICATE

TEST METHOD: IEST RP-CC034.3. H13. MIL-STD 282 / A.S.T.M. - D2986-91. MPPS EN 1822

AEROSOL PHOTOMETER: TDA-2G
SERIAL#: 13235

AEROSOL GENERATOR: LASKIN NOZZLE GENERATOR 4B
SERIAL#: 28399

AEROSAL USED: PAO-4 OIL

VACUUM MODEL: OMEGA SERIES

FILTER: OF612HE-IC

SERIAL No: 170001

PENETRATION RESULT: 0.015

EFFICIENCY: 99.985%



TESTED BY:

Frank Mambro

Technical Director